

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7770-0533:105 Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: Viking Corp., 210 N. Industrial Park Rd., Hastings MI 49058
Contact: Eldon Jackson (269) 945-9501 FAX (269) 945-9599

DESIGN: Model E-1, E-2, E-3 and E-4 Deluge, Single/Double-Interlock valves, and Models H-1, H-2, H-3 and H-4 Firecycle III Wet, Deluge, Single/Double-Interlock valves in 1-1/2, 2, 3, 4 and 6 in. piping system sizes, for connection and use in deluge, standard and fail-safe pre-action single/double-interlock Total Pac2 and Firecycle III sprinkler systems, 250 psig rated pressure. Total Pac2 consists of Firecycle III, Model E2 release control panel or a Model Par-3, B-2 release control panel. Refer to listee's data sheet for system operational requirements and electrical rating.

RATING: 250 psig rated pressure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Refer to listee's data sheet for other required/optional accessories.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire sprinkler water control valves used in conjunction with Total Pac2 release device panels for releasing Viking Models E-1, E-2, E-3, E-4 and H-1, H-2, H3 and H-4 fire sprinkler valves.

NOTE: Models B-2 and E-2 release panels are not approved for use as building fire alarm control panels. For actuating fire sprinkler solenoid valves only as noted above.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 4, 2007

Listing Expires June 30, 2008

Authorized By:

MIKE TANAKA, Senior Deputy State Fire Marshal
Program Manager